



An ISO 9001: 2015 & OHSAS 18001:2007 Certified Company.  
Member of National Safety Council India

# Surya Fire Safety Enterprises

A/Post- Chandapuri, Piliv, Tal- Malhiras, Dist.-Solapur Pin Code-413310 (Maharashtra- India).  
Mob-9637348585, 9545149193 Web- [www.suryafiresafety.com](http://www.suryafiresafety.com) E-Mail: [suryafiresafety22@gmail.com](mailto:suryafiresafety22@gmail.com)

Ref. No: SFDL23-24/01

Date: 03/04/2023

## CERTIFICATE

### TO WHOME SO EVER IT MAY CONCERN

This is to certify that following fire extinguisher installed on the premises of M/s. D Y Patil High School. AT:- D. Y. Patil Technical Campus, Sr. No. 124 & 126, A/p Ambi, MIDC Road, Tal Maval, Talegaon Dabhade, Maharashtra 410507.

Has been supplies by our company as per IS 15683 standards on  
03 APRIL. 2023.

Sr. No:	Type of Fire Extinguisher	Serial No.	Hydro Testing Pressure	Working Pressure	Remark
1	ABC Powder Base Stored Pressure Type Fire Extinguisher Cap-6kg.	3800, 3820, 3798, 3738,	28 Bar	14 Bar	Satisfactory
2	ABC Auto Modular Powder Base Type Fire Extinguisher Cap-5kg.	7532.	28 Bar	14 Bar	Satisfactory

Total Fire Extinguisher – 05Nos.  
Next Due Date of Refilling: - 2 APRIL 2024.  
For Surya Fire Safety Enterprises

